# **DATA PACKAGE INFORMATION SHEET**

Applicant Information	Name / Ad	TIF Idress: N//		
	Standard:	IEC 60950	-1:2005	(Second Edition); Am1:2009 +
5	Am2:2013			
Information	-			tation
	-	Base trans		
	Models:	Open Cellu	ular Con	nect-1 GSM BTS
Test Location Information	nam only Authorized or TCP Re	en all tests a e of the pe , signature d Signatory eviewer:	Sign Print Date	Abraham Alganes  ducted by one person, the printed name can be inserted here; otherwise, the nducting the test shall be entered on each page containing data (printed name uired).
	UL WTDP Witness:	/ WMT	Sign Print	
Reviewed & Accepted	Qualified F Handler:	Project	Sign	Paul Pham Paul Pham/ Handler

# **LIST OF TESTS**

**Special Instructions** - Unless specified otherwise in the individual Methods, the tests shall be conducted under the following ambient conditions. Confirmation of these conditions shall be recorded at the time the test is conducted.

<u>Standard</u>	<u>Ambient</u>	Temper	ature, °C	Relative Humidity, %	Barometric Pressure, mBar
		± _		±	±_
60065	25	±	10	Max 75	Not specified
60601-1	+1	10 to +40	)	30 to 75	700 to 1060 hPA
60950	Not	t specifie	ed	Not specified	Not specified
60950-1	Not	t specifie	ed	Not specified	Not specified
61010-1	+1	15 to +35	5	Max 75	75 to 106 kPa
61215	Not	t specifie	ed	Not specified	Not specified
61646	Not	t specifie	ed	Not specified	Not specified
61730	Not	t specifie	ed	Not specified	Not specified

## RISK ANALYSIS RELATED TO TESTING PERFORMANCE:

The following types of risks have been identified. Take necessary precautions. This list is not all inclusive.

The following types of fisks have been identified.	Take necessary precautions. This list is not all inclusive
[X] Electric shock	[] Radiation
[X] Energy related hazards	[] Chemical hazards
[X] Fire	[] Noise
[] Heat related hazards	[] Vibration
1 Mechanical	<b>[X]</b> Other (Specify) Explosion

File E484144 Project 4787920792 File Date Page 3 of 11

Witness Test Data Program (WTDP) I	ntormation:			
Environment:				
Accommodations and Environmental requirements of the test standard or U 5.3.3, 5.3.4)				]Yes [ ]No [ ]N/A
Personnel:				
Lab Management shall authorize perstesting. (ISO/IEC 17025 5.2.5)	sonnel to operate par	rticular types of equip	oment used in	[ ]Yes [ ]No
Equipment:				
Testing is being conducted within the Information Page and ISO/IEC 17025			est Instrument	[ ]Yes [ ]No
Calibrations for testing equipment is t (Calibration Certificate Analysis. (ISC			032	[]Yes[]No
Critical Consumables:				
Critical consumables are compliant w 4.6)	rith test standard requ	uirements. (ISO/IEC	17025 Clause <b>[</b>	]Yes [ ]No [ ]N/A
Sample Identification:				
Identification of items to be tested has Test Sample Identification page and I			etc.) (See	[ ]Yes [ ]No
Summary:				
The test facility [was] [was not] deem to perform the tests included in this definition.		onment and capabiliti	es necessary	
[ ] The CAS Staff as indicated below, (a was utilized to conduct the witnessing of document the rationale and approval.)				
Name of UL Staff   CCN/Standard to	Test(s) to be	L1, L2 or L3	Similar	L3 Reviewer

Name of UL Staff conducting WTDP	CCN/Standard to be witnessed	Test(s) to be witnessed	L1, L2 or L3 Competency	Similar CCN/Standard Competency	L3 Reviewer Approval & Date (Similar CCN/Standard)

[ ] The Field Services Staff Member, as indicated below, (with a competent program competency as authorized by the FOM) was informed and utilized to conduct the witnessing of tests on behalf of the project handler. (Please complete the table below to document the information and approval.)

Name of UL Staff conducting WTDP	CCN/Standard to be witnessed	Test(s) to be witnessed	FOM Approver (name)	L3 Reviewer Approval & Date (Similar CCN/Standard)
				,

[

# **TEST SAMPLE IDENTIFICATION**

The table below is to provide correlation of sample numbers to specific product related information. Refer to this table when a test identifies a test sample by "Sample No." only.

Sample Number	Sample Card Number	Date Received	Manufacturer, Product Identification and Ratings
1	1262358	2017-11-15	Facebook, Base transceiver station, model Connect-1 GSM BTS, 16-24 Vdc, 3A  48 Vdc PoE, 1.5A  (provided from external power source)
	_	_	
Sampling Proce	dure (if used):		

# TO BE COMPLETED BY STAFF CONDUCTING THE TESTING:

TEST LOCATION:							
[X]UL or Affiliat	e []WTDP	[]CTDP	[]TPTDP	[]TCP	[]PPP		
	[]WMT	[]TMP	[]SMT				
Company Name	UL LLC						
Address	47173 Benio	ia St. F	remont, CA	94538-736	66 USA		

ı
INK(s) TO
OTHER UI
LOCATIONS WHERE
ADDITIONAL TE
ST DATA/OBSERY
VATIONS ARE STORED:

Link to separate data files for a test can be inserted here. The link must be a server that is accessible to UL staff, that provides for backup, required retention periods and a path, including file name that does not change and result in a broken link. Not applicable to DAP.

Test Name	Full Link to Location

# TEST INSTRUMENTS REFERENCE LIST

[X]UL test equipment information is recorded on Meter Use in UL's Laboratory Project Management (LPM) database.

Instr.	Instrument	Instrument	Instrument Range Used	Make and Madal **	Calibrat	Calibration Date		
Code	I.D.	Type	Range Used Or ***	Make and Model **	Last	Due		
	See Meter Use in Aurora							

"Chamber setting(s) [ was ] [ were ] monitored to ensure that the setting(s) [ was ] [ were ] stable throughout the test time frame. Any deviations from the setting(s) are noted below.

Date	Test	Instrument Code	Time period of deviation	Setting(s)

<sup>\*\*</sup> Information to be recorded when tests are conducted at a non-UL facility.

<sup>\*\*\*</sup> Refer to specific data sheet for individual scale used.

File E484144 Project 4787920792 Print date 2017-11-15 Page 6 of 11

Tested by:	Abraham Alganes	Tested by:		Test date:	2017-11-16
	signature		print		
Sample #:	1	Instrument Code / Ran	ge:		
2.2.2, 2.2.3,	2.2.4, PART 22 6.1 - SELV R	ELIABILITY TEST INCL	UDING HAZARDOL	IS VOLTAGE	MEASUREMENTS
METHOD					
voltages bet	s conducted after the Working [ V ac, Hz ] [ 48 V dc loween the following points were eding SELV limits (t1) and	POE] and operated norre measured. If the fault	nally. After the intro condition resulted in	duction of a f	ault, as noted below,
RESULTS					
	<del>[ V ac, Hz</del> ] [ 48 V dc l	POE]			

Component (measured between)		ng components in SELV cir max. voltage (V) (normal operation)		Voltage Limiting Components		
		V peak	V d.c.			
PV18POE		20.8Vpk	19.3Vrms	T3 transformer		
Fault test perf	test performed on voltage limiting components  Voltage measured (V) in SELV circuits  (V peak or V d.c.)		usured (V) in SELV circuits // peak or V d.c.)			
T3 (short pin s	5 to pins 7, 8, 9)	19.13Vrms / 20.8Vpk				
T3 (short pin s	5 to pins 10, 11, 12)	19.11Vrms / 20.8Vpk				
T3 (short pins	1, 2 to pins 7, 8, 9)	22.27Vrms / 36.0Vpk				
T3 (short pins	1, 2 to pins 10, 11, 12)	21.63Vrms / 36.0Vpk				
T3 (short pins	3, 4 to pins 7, 8, 9)	19.23Vrms / 20.8Vpk				
T3 (short pins 3, 4 to pins 10, 11, 12)		21.75Vrms / 28.0Vpk				

ULS-60950-1-2nd A2-2013

Doc. R\_19\_17

Form Issued: 2013-09-03 Revised: 2014-04-15

File	E48414	4 Project	4787920792	Print date	2017-11-15	Page 7 of 11
Teste	ed by:		Tested by:		Test da	ite:
0		signature	- Lyatan arat Oa	print		
Sam	ple # : _	_	_ Instrument Co	de / Range:		_
2.2.2	, 2.2.3, 2	.2.4, PART 22 6.1 - SELV I	RELIABILITY TES	ST INCLUDING HAZ	ZARDOUS VOLTA	AGE MEASUREMENTS
		ecord the time duration for 0 V dc for outdoor equipme			V dc for indoor e	equipment, or 15 V r.m.s.,
[X ]	[x] 71	the fault was introduced, the Vpk or 120 Vpk and after for voltages having a repetiti (42.4 V peak or 60 Vdc) following conditions:  a) if $t_1 \le 20 \text{ ms}$ , $t_2 \text{ shall}$ b) if $t_1 > 20 \text{ ms}$ , $t_2 \text{ shall}$ c) $t_1 \text{ shall}$ not exceed 200	0.2 seconds the vive nature after a but not exceeding be greater than 1 be greater than 3	voltage did not excee fault (for example, fr ng V2 (71 V peak or 7 1 s;	rom power supplie	es in "hiccup" mode), V1
[]	[] 30 30	for Equipment, after the fault of V r.m.s., $42.4 \text{ V}$ pk or $60 \text{ V}$ of $0 \text{ V}$ dc. In voltages having a repetitive (15 V r.m.s., $21.2 \text{ V}$ pk of pulses exceeding were part of the fit of the point of the pulses of t	V dc and after 0.2  ve nature after a for 30 V dc) but not bermitted under the greater than 1  be greater than 3	2 seconds, the voltage fault (for example, from the exceeding V2 (30 Value following condition 1 s;	ge did not exceed om power supplie / r.m.s., 42.4 V pl	es in "hiccup" mode), V1
Com	ments:					


## NOTES TO LAB:


- 1. Conduct the Hazardous Voltage (Circuit) Measurement Test (2.10.2) first.
- 2. Since short term peak voltage is of interest during tests involving a fault, voltages should be monitored by using an oscilloscope for the first two seconds after any failure is introduced. If necessary, a photo of the waveform should be taken, marked with the settings, and attached to this sheet.
- Contact engineer if:
  - A. A limit of 71 V pk or 120 Vpk is exceeded for indoor equipment.
  - B. A limit of 42.4 V pk or 60 V dc is exceeded for more than 0.2 seconds for indoor equipment.
  - C. A limit of 30 V r.m.s., 42.4 V pk or 60 V dc is exceeded for outdoor equipment.
  - D. A limit of 15 V r.m.s., 21.2 V pk or 30 V dc is exceeded for more than 0.2 seconds for outdoor equipment.
  - E. Equipment enters "hiccup" mode as a result of an abnormal condition and more than one pulse per time period exceeds V1.

ULS-60950-1-2nd A2-2013

Doc. R\_19\_17

Form Issued: 2013-09-03 Revised: 2014-04-15







File E	E484144	Project 4787920792	Print date	2017-11-15	Page 9 of 11
Tested Sample	signature	Tested by:	print  Code / Range:	Test date:	
	LITHIUM BATTERY REV WAIVED PER PROJECT OD				
A dc ar	e lithium battery removed mmeter replaced the batte e current pretection compo	ry in the circuit and th	e normal reverse (charg	ging) current was measu	red. The
RESUL	_TS				
Test Vo	oltage:48_ [ <del>Vac,</del>	<u>Hz</u> ][Vdc POE]			
Battery	Туре	Normal Reverse Charging Current (mA)	Abnormal Condition		Abnormal Reverse Current (mA)
CR-122	20/HFN	3 mA	IC U72B short pin 87 (\(VBAT)\)	/DDC) to pin 68	
CR-122	20/HFN	3 mA	R10285 short		
Comm	nents:				
	on-rechargeable coin batte iant issue shall be address			rging current protection	circuitry; this non-
NOTES	S TO LAB:				
1.	CAUTION: Risk of explo	osion. Remove batter	y before performing this	test.	
2.	Notify engineer if maxim	um abnormal charging	g current exceeds	mA.	
NOTES	S TO ENGINEER:				
1.	This test is conducted to under "Conditions of Acc		normal current specified	I in Recognized Compor	nent Battery Report

ULS-60950-1-2nd A2-2013

Form Issued: 2013-09-03 Doc. R\_19\_70 Revised: XXXX-XX-XX





		 0. 020. 02		Time date		0	r ago 11 oi	• •
Tested by:	Abraham Alganes	Tested by:				Test date:	2017-11-16	
	signature	_		print	<u> </u>			
Sample #:	1	Instrument C	Code / Rang	e:				

Print date 2017-11-15

Page 11 of 11

Project 4787920792

## 5.2.2 - ELECTRIC STRENGTH TEST

#### **METHOD**

File F484144

While the unit was in a well heated condition [ ] after the Heating Test [ ] other method, an ac or dc potential was gradually increased from zero to the test potential given below. The voltage was applied and maintained for a period of one minute between the points indicated.

## **RESULTS**

5.2	TABLE: Electric strength tests, impulse tests and voltage surge tests					
Test voltage From/To	e applied between:	Voltage shape (AC, DC, impulse, surge)	Test voltage (V)	Breakdown Yes / No		
Functional:		'				
Basic/supple	ementary:					
T3 transformer (Pri/ Second windings)		AC	1000	No		
Reinforced:						
Supplement	ary information:	·				
	used to bring sample to "well heated" condition if test is not condition if test is not condition.	ducted after the Hea	ating test:	The unit		
There [ was seconds.	] [ was no ] indication of breakdown as a result of applying the	test voltage to the ir	ndicated loca	ations for 60		

Comments:	The test v	was cond	ucted at 1	1414Vdc	[ADA 20	17-11-16]

## NOTES TO LAB:

- Record time recording instrument under "test equipment" in the main list of test equipment. 1.
- 2. For Electric Strength Test, sub-clause 5.2 and 5.2.2, specify which test voltage "AC" or "DC" was applied to the
- For specialized products which incorporate an AC switches, relays, triacs etc., contact engineer if question about 3. status of component.

ULS-60950-1-2nd A2-2013

Doc. R 19 88

Form Issued: 2013-09-03 Revised: 2017-06-30

Form Copyright © 2012 UL LLC

Created by ULtraLink on 2017-11-15

Only those products bearing the UL Mark should be considered as being covered by UL.